

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:299 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Model TGF-562 fire alarm receiving control unit. Unit is intended for use with listee's Models TFX-500 or TFX-800 fire alarm control units (CSFM Listing Nos. 7165-1493:147, 7170-1493:161, 7170-1493:167). System components:

976281	Mouse
976280	Keyboard
976278, 976279	Monitor
976285	Monitor
976276	Computer
LX-300/976164	Printer
TNI-562/976271	Network Interface
TGX-562	Annunciator

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm receiving control unit for use with listee's Model TFX-500 and TFX-800 fire alarm control units.

NOTE: Formerly 7300-1493:174

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager